

**ADDENDUM TO INVITATION FOR BIDS**  
**Humboldt County Office of Education**  
**Proposition 39**  
**Administration Building Furnace Project – Re-bid**  
**Bid No. 17-023**

**Addendum No. 3**  
**October 24, 2017**

**To All Prospective Bidders:**


**The Humboldt County Office of Education (District) herewith issues Addendum No. 3 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.**

Administrative item:

1. For clarification, there is no Addendum No. 1 for this Invitation for Bids – the first addendum was titled “Addendum No. Two.” Please write Addendum No. 1, dated “none” on the bid proposal form.

Changes/Clarifications to Scope of Work:

2. Disregard the note on drawing A3.01 indicating new R-19 batt insulation for the entire floor of the building. Also, no installation of insulation is to be included in the scope of work in the attic space.
3. An area for staging of equipment and materials for this project has been identified at the north end of the main Administration Building – see green oval shown on attached drawing. Please note that this area will only be available during the installation window from June 18 through August 10, 2018.
4. In Addendum No. Two, “ Item 2.00 – Drawing Clarifications”, part 2.B - the sentence should read: "Where ductwork removal or demolition work occurs in the original ceiling, the resulting holes should be repaired and sealed in a workmanlike manner, using gypsum board or other suitable material, to prevent conditioned air from leaking back into the attic."



Green oval indicates staging area for equipment and materials (image adapted from drawing A1.01)