

ADDENDUM TO INVITATION FOR BIDS

Fortuna Union High School District

Proposition 39

LED Lighting Retrofit, Phase II

Bid No. 17-017

Addendum #2

May 26, 2017

To All Prospective Bidders:

The Fortuna Union High School District (District) herewith issues Addendum No. 2 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. Bid Submittals are now due **June 8, 2017 at 3:00 p.m.**
2. All lighting retrofits for the Gym and associated rooms (Appendix 2, Line items 76 through 86, 96, 97 & 98) have been removed from the scope of work.
3. All lighting controls and sensors (Appendix 2, Line items 15,16,17,19,20,22,26) have been removed from the scope of work.
4. For existing T-12 8' fixtures with magnetic ballasts (Appendix 2, Line items 27,33,34,37,91), install T-12 to T-8 conversion kit with new compatible LED driver and (4) 4' TLEDs.
5. For Line item 36, Parts Room, assume fixture retrofit instead of new fixture installation.
6. For bid purposes, include the cost of an additional 15 new replacement fixtures, Lithonia LBL4 30L LP850 or equivalent, with locations of the new fixtures to be determined prior to installation. If less than 15 fixtures require replacement, the cost of un-installed fixtures will be credited to the District upon project completion.
7. No existing suspended fixtures should be raised.
8. For bid purposes, an additional 250 replacement tombstones and 100 narrow, 2 x 4' wrap fixture replacement lenses have been added to the scope of work, to be installed when needed. The cost of un-used tombstones and lenses, if any, to be credited to the District upon project completion.