

**ADDENDUM TO INVITATION FOR BIDS**  
**Cutten Elementary School District**  
**Proposition 39**  
**Cutten Elementary School LED Lighting Project**  
**Bid No. 17-010-02**

Addendum #1  
May 18, 2017

To All Prospective Bidders:

The Cutten Elementary School District (District) herewith issues Addendum No. 2 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

Clarification and additions to the Scope of Work:

1. Base Bid:
  - a. Existing hangers will be reused to hang new fixtures.
  - b. District will be responsible for any ceiling tile repair or replacement due to moving the fixtures.
  
2. Additive Alternate 1:
  - a. Fixture mounted daylight sensors will be installed on each of the (66) new fixtures.
  - b. The District may choose to do half the fixtures, closest to the windows, and will make the final determination before awarding the contract.
  
3. Additive Alternate 2:
  - a. For area G: Staff Room, install a single occupancy sensor with a power pack to intercept switch leg line power. Sensor shall be able to cover the whole room.
  - b. For Area H: Staff Room Bathroom, the occupancy sensor will control both the light and the fan.