

ADDENDUM TO INVITATION FOR BIDS
Fieldbrook Elementary School District
Proposition 39
HVAC Upgrade Project
 Bid No. 17-016

Questions and Clarifications Memo #1
 May 24, 2017

- Question: There are 13 forced air furnaces, which two are to remain?

The two forced air furnaces that will remain and not be replaced include the music room/stage and the Multipurpose room furnace that is located in the Maintenance Office. Below is a map showing the units to be replaced in green and the units to remain in red.

Also for the direct vent heaters, only the PTAC in the Staff Work Room will be replaced and the duct removed, and the heater in the superintendants office will remain. These are also shown on the map.

