

**ADDENDUM TO INVITATION FOR BIDS**  
**Fortuna Elementary School District**  
**Proposition 39**  
**Fortuna Middle School LED Lighting Project**  
Bid No. 17-012

Addendum #1  
April 19, 2017

To All Prospective Bidders:

The Fortuna Elementary School District (District) herewith issues Addendum No. 1 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. The Installation start date shall be revised to Monday, June 19<sup>th</sup>, 2017.
2. The Installation completion date shall be revised to Friday, July 21, 2017.
3. The Scope of Work page 5 sections 1 and 2 will be replaced by the revised Scope of Work sections 1, 2 and 3 attached to this Addendum.

Summary of Scope of Work changes:

- Addition of specifications for the High Bays.
  - Addition of specifications for the LED lamp replacements.
  - Additional areas added for LED lamps replacements.
  - Addition of emergency lights and exit signs.
4. The Bid Proposal Form pages 15 and 16 will be replaced in its entirety with a revised Bid Proposal Form, attached to the Addendum.

Summary of changes to Bid Proposal Form:

- Update to the Description of the measures to be bid.

## SCOPE OF WORK

---

### 1. Replace twenty-four (24) existing 300W induction high bays with (24) new LED high bays, 240W, 5000 K.

| Existing     |                 |                     |           | Proposed  |
|--------------|-----------------|---------------------|-----------|---|
| Fixture Type | Qty of Fixtures | Fixture Description | Mounting  | Fixture Type                                      |
| High Bay     | 24              | 300W Induction      | Suspended | 240W LED High Bay, 5000K (Cree CXB or equivalent) |

- a. Fixtures will have twist lock plugs.
- b. Existing banked switching will be used to shut off half of the high bay fixtures at each switch. Switching pattern will be determined by the District before installation.
- c. Fixtures will be bell shaped with a prismatic reflector, open bottom with impact cage.
- d. Light output will be between 24,000 and 30,000 lumens.
- e. Color temperature will be 5000 K.

### 2. Retrofit (32) 2-lamp fluorescent fixtures and (14) 1-lamp PLC fixtures with new LED lamps.

| Area               | Qty of Fixtures | Lamps per Fixture | Qty of Lamps | Lamp Type | Proposed Lamp Type   |
|--------------------|-----------------|-------------------|--------------|-----------|--|
| Gym                | 18              | 2                 | 36           | T8        | Ballast Bypass 12W LED T8, 5000K (Eiko LED 12WT8/PRM/48/850 or equivalent) |
| Maintenance Office | 3               | 2                 | 6            | T8        | Ballast Bypass 12W LED T8, 5000K (Eiko LED 12WT8/PRM/48/850 or equivalent) |
| Restrooms          | 2               | 2                 | 4            | T8        | Ballast Bypass 12W LED T8, 5000K (Eiko LED 12WT8/PRM/48/850 or equivalent) |
| Lobby              | 10              | 1                 | 10           | PLC       | Bypass Ballast 8W LED PLC G24-Base, 5000 K (Hero-LED G24Q or equivalent)   |
| Changing Room      | 4               | 2                 | 8            | T8        | Ballast Bypass 12W LED T8, 5000K (Eiko LED 12WT8/PRM/48/850 or equivalent) |
| Janitor            | 1               | 2                 | 2            | T8        | Ballast Bypass 12W LED T8, 5000K (Eiko LED 12WT8/PRM/48/850 or equivalent) |
| Storage            | 4               | 2                 | 8            | T8        | Ballast Bypass 12W LED T8, 5000K (Eiko LED 12WT8/PRM/48/850 or equivalent) |
| Stage              | 4               | 1                 | 4            | PLC       | Bypass Ballast 8W LED PLC G24-Base, 5000 K (Hero-LED G24Q or equivalent)   |

- a. Existing lamps and ballasts will be removed and properly disposed of.
- b. Ballast will be bypassed and new lamps will be installed on existing pins or tombstones per manufacturer's instructions.
- c. Lamps will be 5000 K.

- 3. Replace five (5) exit signs with LED exit signs with bug-eye emergency lighting and impact cages.**

## BID PROPOSAL FORM

---

Governing Board

**Error! Reference source not found.** School District

Dear Members of the Governing Board:

The undersigned, doing business under the name of \_\_\_\_\_, having carefully examined the location of the proposed work, the local conditions of the place where the work is to be done, the Notice Inviting Bids, the General Conditions, the Instructions to Bidders, the Plans and Specifications, and all other Contract Documents for the proposed **Error! Reference source not found.** Project ("Project"), and having accurately completed the Bidder's Questionnaire, proposes to perform all work and activities in accordance with the Contract Documents, including all of its component parts, and to furnish all required labor, materials, equipment, transportation and services required for the construction of the Project in strict conformity with the Contract Documents, including the Plans and Specifications, as follows:

BID:

| <i>Description</i>   | <i>Total Installed Cost</i> |
|--|-----------------------------|
| Replace twenty-four (24) existing 300W induction high bays with (24) new LED high bays, 240W, 5000 K | \$                          |
| Retrofit (32) 2-lamp fluorescent fixtures and (14) 1-lamp PLC fixtures with new LED lamps            | \$                          |
| Replace five (5) exit signs with LED exit signs with bug-eye emergency lighting and impact cages.    | \$                          |

For the sum of: \_\_\_\_\_ dollars (\$).

The undersigned has checked carefully all the above figures and understands that the District is not responsible for any errors or omissions on the part of the undersigned in making this bid.

Enclosed find certified or cashier's check no. \_\_\_\_\_ of the \_\_\_\_\_ Bank for \_\_\_\_\_ Dollars (\$ \_\_\_\_\_) or Bidder's Bond of the \_\_\_\_\_ surety company in an amount of not less than ten percent (10%) of the entire bid. The undersigned further agrees, on the acceptance of this proposal, to execute the Contract and provide the required bonds and insurance and that in case of default in executing these documents within the time fixed by the Contract Documents, the proceeds of the check or bond accompanying this bid shall be forfeited and shall become the property of the District.

Contractor agrees to commence the work within the time specified in the Notice to Proceed. It is understood that this bid is based upon completing the work within the number of calendar days

ADDENDA:

Receipt of the following addenda is hereby acknowledged:

|                  |              |                  |              |
|------------------|--------------|------------------|--------------|
| Addendum # _____ | Dated: _____ | Addendum # _____ | Dated: _____ |
| Addendum # _____ | Dated: _____ | Addendum # _____ | Dated: _____ |
| Addendum # _____ | Dated: _____ | Addendum # _____ | Dated: _____ |

Respectfully submitted,

Company: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

By: \_\_\_\_\_

*(Please Print or Type)*

Signature: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_

Telephone: \_\_\_\_\_

Contractor's License No: \_\_\_\_\_ Expiration Date \_\_\_\_\_

Required Attachments:

- 1) Subcontractor List Form
- 2) Workers' Compensation Certificate
- 3) Non-Collusion Affidavit
- 4) Bid Bond (or Cashier's or Certified Check)
- 5) Bidder's Questionnaire