

**ADDENDUM TO INVITATION FOR BIDS**  
**Mattole Unified School District**  
**Proposition 39**  
**Mattole Elementary HVAC Upgrade Project**  
Bid No. 17-018

Addendum #2  
June 14, 2017

To All Prospective Bidders:

The Mattole Unified School District (District) herewith issues Addendum No. 2 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. Changes to the Scope of Work:

The unit serving B3 was identified as a packaged Heat Pump unit and does not have gas service to it. This unit shall be replaced by a 3.0 Ton packaged Heat Pump, SEER 14 or higher, Rheem RQPMA037JK000 or equivalent.

2. The third row of the table in Appendix A shall be replaced by the following:

<b>Area Served by unit</b>	<b>Description of Measures</b>	<b>New Equivalent Tonnage</b>	<b>Qty</b>	<b>Existing Tonnage</b>	<b>Existing Unit</b>
B3: Classroom Grades 3-5	Replace packaged Heat Pump unit serving the classrooms with new packaged Heat Pump unit, SEER 14 or higher.	3.0	1	3.0	No Nameplate information