

**ADDENDUM TO REQUEST FOR QUOTES**  
**Fortuna Union High School District**  
**Proposition 39**  
**Streetlighting LED Upgrade**

**Addendum #1**  
**March 23, 2018**

**To All Prospective Bidders:**

The Fortuna Union High School District (District) herewith issues Addendum No. 1 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. The Proposed fixtures in the 3 areas listed as the base bid are changed as follows:

Streetlights should be on the California PG&E Qualified Product List (QPL), rated at between 75-85W for 150-200W replacements, and between 95-105W for 250-400W replacements. Two representative streetlights are:

- 85W Type 2 LED Streetlight (Acuity Autobahn ATB0 30BLEDE85 XXXXX R2 5K)
- 104W Type 3 LED Streetlight (Acuity Autobahn ATB0 30BLEDE10 XXXXX R3 5K)

Revised table for Base Bid (changes shown in italics):

<b>Area Name</b>	<b>Existing Fixture</b>	<b><i>Proposed Fixture (Revised March 23, 2018)</i></b>	<b>No. of Fixtures</b>
East Parking Lot near District Office	200W HPS Streetlight	<i>75-85W Type 2 LED Streetlight (Acuity Autobahn ATB0 30BLEDE85 XXXXX R2 5K or similar)</i>	1
Ticket Office	~250W HPS Streetlights	<i>95-105W Type 3 LED Streetlight (Acuity Autobahn ATB0 30BLEDE10 XXXXX R3 5K or similar)</i>	2
Baseball Diamond	150W HPS Streetlight	<i>75-85W Type 2 LED Streetlight (Acuity Autobahn ATB0 30BLEDE85 XXXXX R2 5K or similar)</i>	1