

ADDENDUM TO INVITATION FOR BIDS
Mattole Valley Charter School
Proposition 39
Caspar Creek Learning Academy Lighting Upgrade
Bid No. 18-001

Addendum #2
March 12, 2018

To All Prospective Bidders:

The Mattole Valley Charter School (MVCS) herewith issues Addendum No. 2 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. The Scope of Work, Section 1.c.i shall be updated to read:
 “Provide and install three (3) new mini-split ductless heat pump indoor wall-mounted units. One (1) 18,000 btu/h heating capacity (MSZ-GL18NA or equivalent) and two (2) 12,000 btu/h heating capacity (MSZ-GL12NA or equivalent) mini-split ductless heat pump indoor wall-mounted units.

2. The Scope of Work, Section 1.c.ii shall be updated to read:

Provide and install one (1) new 45,000 btu/h capacity, 19 SEER and 11 HSPF multi-zone mini-split ductless heat pump outdoor unit (MXZ-4C36NAHZ).