

**ADDENDUM TO RFQ/RFP**  
**Cuddeback Union School District**  
**Proposition 39**  
**Solar PV System**

**Addendum #2**  
**June 6, 2018**

To All Prospective Proposers:

The Cuddeback Union School District (District) herewith issues Addendum No.2 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the proposer shall acknowledge receipt thereof in their Proposals. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. The Cuddeback School location does not have a strong wireless signal. The solar contractor will ensure that their design includes all requirements for monitoring of PV output data and sending that data to the District's chosen IP address or web portal including but not limited to cabling, modems or inverter COM cards.
2. Selected sheets from the original 1957 building plans that show relevant framing details for the classroom building roof are attached.