

ADDENDUM TO INVITATION FOR BIDS
Northern Humboldt Union High School District

Proposition 39
MHS Library HVAC Project
Bid No. 19-905

Addendum #1
May 1, 2019

To All Prospective Bidders:

The Northern Humboldt Union High School District (District) herewith issues Addendum No. 1 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the bidder shall acknowledge receipt thereof on the Bid Proposal Form. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. In the Scope of Work, Item 1.f is revised as follows:
 - a. Temperature Controls
 - i. Existing control system shall be used to control new furnaces, if possible.
 - ii. If existing control is not compatible with new furnaces, a thermostatic control should be installed to control all of the furnaces.