

ADDENDUM TO RFQ/RFP

**Kneeland Fire Protection District
Grid Tied Solar Plus Storage Project**

**Addendum #1
February 12, 2020**

To All Prospective Respondents:

Kneeland Fire Protection District (District) herewith issues Addendum No. 1 to the above-referenced solicitation. This Addendum shall be made part of the Contract Documents and the proposer shall acknowledge receipt thereof in their Proposals. Except as specifically modified by this document, all other terms and conditions remain in full force and effect.

1. The Statement of Work is hereby amended to include:

“Additive Alternate B: Include incremental price increase for a bidirectional inverter for the Battery Energy Storage System that is also capable of accepting generator input and will be able to charge the battery storage system during prolonged grid outages.”

- 2. Electronic submission of Proposals will be accepted and are due March 12, 2020 at 3:00 pm.*** Disregard language on page 8 of the original solicitation stating that “fax or email proposals will not be accepted”.
- 3. Disregard language on page 5 regarding “operation of all new equipment including the new on-demand water heater”.***
- 4. RCEA’s Feasibility Study is provided as reference and for informational purposes only.***