

Addendum No. 1
TO
REQUEST FOR QUALIFICATIONS AND
REQUEST FOR OFFERS
FOR
MID-TERM RELIABILITY RESOURCES



Redwood Coast Energy Authority
www.RedwoodEnergy.org

Solicitation issued February 13, 2023
Addenda issued February 25, 2023

procurement@redwoodenergy.org

1 QUESTIONS & ANSWERS

1.1 PRODUCT QUESTIONS

1. ***Will RCEA consider offers for standalone storage for this RFO?***

Standalone energy storage is not eligible for participation in RFP-23-401, as specified in Section 4.1 of the RFO Protocol, if that is the only project being offered. New generating capacity is needed for compliance with the particular CPUC requirement this RFO is aimed to satisfy. However, standalone energy storage would be eligible if the same respondent is also offering a generating resource. The generator does not have to be co-located with the storage, but needs to provide sufficient charging energy and the two resources would be contractually paired.