



IFB-24-501 Addendum No.2: Answers to questions, additional scoping language, additive alternates, and site photos

Questions from Bidders:

1. Question: Regarding the site on sheet 1.2, what are the requirements for the mass and brand of the pole to be installed?

Answer: All pole requirements, including mass and brand, must comply with PG&E Greenbook standards. Per Site Plan Notes on sheet 1.2 "Customer owned pole to comply with PG&E Greenbook section 025055."

2. Question: Who will be responsible and who will pay for the traffic control permit for the site on sheet 5.2 (Sequoia Park) when installing a cable line across the road?

Answer: PG&E will be installing the service line that crosses Dolbeer Street. That work is not in scope for Bidders on this project.

3. Question: Will the owner provide mobile toilets during the work on the tender?

Answer: No

4. Question: Has PG&E approved the meter/switch gear specifications provided on Sheet E1?

Answer: Yes.

Additional Scoping Language:

1. At site #4, Carlson Park, Bidder's scope of work will be delineated as follows:
 - a. City of Arcata will be responsible for:
 - i. Providing and installing the parking lot lights, poles, conduit, conductors, and pull boxes associated with them.
 - ii. Providing and installing the meter switchgear, backboard and 5' utility conduit stub toward utility pole mounted transformer
 - iii. Installing conduit from the meter switchgear to the charging station locations
 - iv. All paving of parking lot stalls
 - b. Bidders will be responsible for all other scope shown on plans.

2. At site #7, Rohner Park, Bidder's Scope of work will not include paving or re-paving of existing parking stalls. Parking stalls will need to be re-marked and re-stripped in accordance with the plans and specification.
3. At site #9, Redwood Rural Health Center, RCEA requests Bidders add a non-traffic rated pull box, to be installed in the landscaped area between the meter switchgear and the charging stations. Pull box to be rectangular, underground, non-traffic rated, Oldcastle L Series 1419-12 or equivalent.

Additive Alternates

RCEA is requesting bidders include the following bid items as Additive Alternates in their bids:

1. Please provide a separate bid item, Additive Alternate #1, for all costs associated with providing and installing/setting the Customer Owned Pole at Site #1 Orleans Fire Department. This Additive Alternate is for the pole only, all other associated electrical equipment/devices shall not be included.
2. Please provide a separate bid item, Additive Alternate #2, for all material costs for a pedestal mounted switchgear assembly that would replace the switchgear and backboard shown on E1. Pedestal mounted switchgear shall be 120/240-volt, single phase, 400-amp, with test bypass provisions, 400-amp main breaker, and minimum of 8 distribution breaker spaces. Customer and utility pull sections must be separated, and utility sections must be lockable. Pedestal mounted switchgear must meet all PG&E Greenbook standards. Bidders may use Millbank 3P3BB11241 or equivalent for bidding purposes. Additive Alternate #2 must also include a written statement from the equipment manufacturer or supply house indicating the lead time to acquire the equipment.

Site Photos

RCEA has recently visited each of the project sites and provides the following photos to bidders to show the existing conditions. However, before submitting a bid for the work, it is recommended that the Bidder inspect the sites and inform themselves as to the conditions under which he will be obligated to execute the work. No allowance will be subsequently made for failure to inspect, and the Bidder will be solely responsible for the consequences of his negligence or lack of diligence. Before submitting any proposal, each Bidder shall examine the General Conditions, Plans, Specifications, as well as these Instructions to Bidders, and the forms appended hereto and made a part hereof.

SITE #1 ORLEANS FIRE DEPARTMENT





SITE #2 AZALEA HALL, MCKINLEYVILLE



SITE #3 MAD RIVER COMMUNITY HOSPITAL



SITE #4 CARLSON PARK, ARCATA





SITE #5 SEQUOIA PARK, EUREKA





SITE #7 ROHNER PARK, FORTUNA





SITE #8 REDWOOD MEMORIAL HOSPITAL





SITE #9 REDWOOD RURAL HEALTH CENTER







SITE #10 412 MAPLE LANE, GARBERVILLE



-End of Addendum No.2-