



IFB-24-504 Addendum No.2:

Questions from Bidders:

1. Can RCEA confirm that both Fortuna locations will have pedestal mounted switchgear installed?

Answer: Only Fortuna's Rohner Park requires the use of pedestal mounted switchgear in accordance with IFB-24-504_Attachment 1.1 Plan Drawing and Technical Specs FORTUNA & EUREKA, sheets 1.2 and 2.2.

2. Would the use of the pedestal mounted switchgear eliminate the disconnect?

Answer: Yes, the pedestal mounted switchgear takes the place of the backboard mounted switchboard (detail 3, sheet E1) in its entirety. No additional disconnect is needed for the pedestal mounted switchgear.

-End of IFB-24-504 Addendum No.-2