

Addendum No. 1
TO
RFO-25-402
REQUEST FOR OFFERS
FOR
LONG-TERM RENEWABLES PORTFOLIO
STANDARD RESOURCES



Redwood Coast Energy Authority
www.RedwoodEnergy.org

Solicitation issued September 30, 2025
Addendum 1 issued October 13, 2025

procurement@redwoodenergy.org

SOLICITATION NUMBER

The RFO was erroneously issued as RFO-25-401 and is hereby edited to RFO-25-402.

QUESTIONS & ANSWERS

The following are answers to questions received by RCEA staff as of the question submission deadline of October 8, 2025.

1. **Will you consider PCC3 products in this RFP?**

No, only PCC1 offers are eligible.

2. **Will RCEA sign an NDA with in order for us to participate in the RFO?**

No, RCEA is unable to accommodate requests to sign an NDA with a potential respondent in order to submit an offer. How RCEA treats confidential information submitted through the RFO is described in Section 3.5 of the RFO Protocol.

3. **What is the expected delivery start date and term length RCEA anticipates under this procurement?**

RCEA anticipates receiving offers with start dates between 2027 and 2031, but will consider offers with earlier or later start dates. RCEA requires a minimum delivery term of ten years in keeping with the state's definition of long-term RPS contracts.

4. **For hybrid resources, should storage output be separately metered and reported, or can it be bundled with renewable generation?**

The storage charging and discharging should be metered separately from generation output to the extent it can. RCEA's proforma PPA contemplates a separate storage facility meter for invoicing purposes.